

OCONEE COUNTY PROCUREMENT OFFICE
415 S. PINE STREET, ROOM 100
WALHALLA, SC 29691
Robyn M. Courtright, CPPO, Procurement Director

Tronda Spearman, CPPB, Assistant Procurement Director

Telephone: 864-638-4141
Fax: 864-638-4142

ADDENDUM NO. 1
ITB 17-01

HERITAGE FARM CENTER TURNING LANE & ENTRANCE ROAD

OPENING DATE: SEPTEMBER 5, 2017 AT 2:00 PM - UNCHANGED

Please include a copy of this Addendum No. 1, signed with your bid. **PLEASE USE THE ATTACHED REVISED BID FORM FOR YOUR BID SUBMITTAL.**

Question 1: Are Rumble Strips needed for this project? There are no Line Items; however, there is a note on Plan Sheet #6 referencing Drawing #633-106-000.

Answer 1: No Rumble strips are to be included.

Question 2: What pavement structure should be used for the Heritage Driveway? The typical only addresses the pavement Structure along US 123.

Answer 2: The pavement structure for the Heritage Driveway should be the same as the pavement structure for US 123.

Question 3: Please clarify: The Line Items call for Graded Aggregate Base Course (8" Thickness); but none is shown on the plan typical. Asphalt Base Course is called out on the plans (Typical Sheet #3), but there is no line item for that work. Which is to be used – or both?

Answer 3: Asphalt Base as per plan. This line item on the Bid Form has been revised.

Question 4: Can the excess dirt (if any) be placed onto the Heritage Farm Center Property for future use?

Answer 4: There should be little if any excess material left, so yes, the contractor will be allowed to leave spoil on the Heritage property.

Question 5: Please verify the asphalt quantities. There looks to be twice as much Intermediate course as surface course (400 lbs/SY vs 200 lb/SY); however, the bid form line items indicate the same quantity.

Answer 5: This line item has been replaced on the Revised Bid Form attached to this Addendum.

Question 6: Please verify permanent construction sign quantities based on Scheme "D" (605-010-02) since there is a grass median along US 123 in this area; 184 SF is not enough quantity to cover both directions on US 123. Also, are there any Perm Construction Signs to be placed on Old School House Road?

Answer 6: There is 24 feet added to line item for side road. This quantity is revised on the Revised Bid Form.

Question 7: There appears to be Clearing and Grubbing work. Does the county wish to include a line item or should be incorporate the cost for this work in other line items?

Answer 7: Minimal Clearing and Grubbing work is required. Incorporate this cost into other line items.

Question 8: What is the construction budget and start date for this project?

Answer 8: We do not disclose the estimated construction budget for our bids, only we will say that it will be over \$50,000 since that is our sealed bid limit. The earliest start date would be September 20, 2017 after we receive Council approval at the September 19 Council meeting.

Please include a copy of this Addendum No. 1, signed with your bid. **PLEASE USE THE ATTACHED REVISED BID FORM FOR YOUR BID SUBMITTAL.**

END ADDENDUM NO. 1

Dated: August 24, 2017

Please acknowledge receipt of Addendum by signing and attaching to your bid.

BY: _____ DATE: _____
(Contractor)

(Signature) (Title of Signing Officer)

COUNTY OF OCONEE
Procurement Office, 415 S. Pine Street, Room 100, Walhalla, SC 29691
Phone: (864) 638-4141 / Fax: (864) 638-4142

REVISED BID FORM

BID NUMBER: 17-01 **DATE:** August 18, 2017

OPENING DATE AND TIME: September 5, 2017, at 2:00pm EST

OPENING LOCATION: Oconee County Procurement Office
 County Administrative Building, Room 100
 415 S. Pine Street, Walhalla, SC 29691

PROCUREMENT OF: Heritage Farm Turning Lane and Entrance Road

Approx Qty	Unit	Description	Unit Price	Total Estimated
NEC	LS	MOBILIZATION		
NEC	LS	BONDS AND INSURANCE		
1.000	EA	CONSTRUCTION STAKES, LINES & GRADES		
NEC	LS	TRAFFIC CONTROL		
1,000.000	CY	UNCLASSIFIED EXCAVATION		
2280.00	SY	FINE GRADING		
10.000	TON	MAINTENANCE STONE		
900.00	TON	HOT MIX ASPHALT BASE COURSE – TYPE A		
80.00	TON	LIQUID ASPHALT BINDER PG64-22		
26.500	SY	MILLING EXISTING ASPHALT PAVEMENT 2.0"		
430.00	TON	HOT MIX ASPHALT INTERMEDIATE COURSE TYPE B		
215.00	TON	HOT MIX ASPHALT SURFACE COURSE TYPE B		
208.00	SF	PERMANENT CONSTRUCTION SIGNS (GROUND MOUNTED)		
200.000	LF	4" WHITE BROKEN LINES -(GAPS EXCLUDED)-FAST DRY PAINT		
900.000	LF	4" WHITE SOLID LINES (PVT. EDGE LINES)-FAST DRY PAINT		
75.000	LF	24" WHITE SOLID LINES (STOP/DIAGONAL LINES)-FAST DRY PAINT		
3.000	EA	WHITE SINGLE ARROW (LEFT, STRAIGHT, RIGHT)-FAST DRY PAINT		
3.000	EA	WHITE WORD MESSAGE "ONLY"-FAST DRY PAINT		
1.000	EA	WHITE COMBINATION ARROW(STR.& RT.OR STR.& LT.)FAST DRY PAINT		
1,000.000	LF	4"YELLOW SOLID LINE(PVT.EDGE&NO PASSING ZONE)-FAST DRY PAINT		
200.000	LF	4" WHITE BROKEN LINES(GAPS EXCL.)THERMOPLASTIC- 90 MIL.		

REVISED BID FORM (Page 2)

900.000	LF	4" WHITE SOLID LINES (PVT. EDGE LINES) THERMO.- 90 MIL.		
75.000	LF	24" WHITE SOLID LINES (STOP/DIAG LINES)- THERMO.-125 MIL		
3.000	EA	WHITE SINGLE ARROWS (LT, STRGHT, RT) THERMO.-125 MIL.		
3.000	EA	WHITE WORD MESSAGE "ONLY" - THERMOPLASTIC - 125 MIL.		
1.000	EA	WHITE COMBINATION ARROWS(STR&RT.OR STR<)THERMO-125MIL		
1,000.000	LF	4" YELLOW SOLID LINES(PVT.EDGE LINES) THERMO-90 MIL.		
18.000	SF	FLAT SHEET, TYPE III, FIXED SZ. & MSG. SIGN		
28.000	LF	U-SECTION POST FOR SIGN SUPPORTS - 3P		
264.000	LF	18" SMOOTH WALL PIPE		
70.000	LF	CLEANING EXISTING PIPE		
1.000	EA	DROP INLET (24" X 36")		
1.000	EA	JUNCTION BOX - CONVERT DROP INLET 24" X 36"		
15.000	TON	RIP-RAP (CLASS B)		
30.000	SY	GEOTEXTILE FOR EROSION CONTROL UNDER RIPRAP(CLASS 2)TYPE D		
0.222	MSY	PERMANENT VEGETATION		
0.222	MSY	TEMPORARY VEGETATION		
0.944	MSY	SODDING		
0.623	MSY	TEMPORARY EROSION CONTROL BLANKET (ECB)		
40.000	LF	SEDIMENT TUBES FOR DITCH CHECKS		
300.000	LF	SILT FENCE		
255.000	SY	STABILIZED CONSTRUCTION ENTRANCE		
			Bid Form Bid Total	

Current Registered South Carolina General Contractors License Number: _____

SCDOT Pre-Qualification Number: _____

FIRM NAME: _____

SIGNATURE: _____ Title: _____

Print Signature: _____ Date: _____

By signing this Bid Form, the Bidder acknowledges that he/she has read this document and understands the provisions, agrees to be bound by its terms and conditions, will adhere to scheduling requirements stated herein and is capable of providing all required products and/or services.